

VVTA RFP 2018-17 BATTERY ENERGY STORAGE AND DEMAND RESPONSE ADDENDUM NO. 2

Thursday, August 30, 2018

This addendum is provided to all known prospective proposers for clarification of the subject Request for Proposal (RFP).

The following are questions received prior to the deadline for questions on Friday, August 24, 2018, at 5:00 PM (PDT) and the responses from VVTA Staff:

Q1: "Please confirm if this project will be subject to the "Buy America" and "Fly America" Requirements. Are you willing to go through the waver process for the Buy America requirement?"

A1: This project is not being funded by Federal Funds.

Q2: "Is fire suppression a mandatory requirement?"

A2: Only if you think it is necessary or required by a building code.

Q3: "What type of structure are you looking for to protect the ESS unit? All of our units are NEMA 3r and do not require additional components to protect it from the elements."

A3: This is entirely up to the proposer.

Q4: "We prefer to use the area next to the trash compactor for the ESS unit. Is that ok?"

A4: There is no room there for the system.

Q5: "Can the 240 calendar days to be completed be extended?"

A5: Yes, state a timeline in your proposal.

Q6: "There are 2 ports on each of the chargers. Can we assume the max charge rate is 50% of the 125KW?"

A6: Chargers are 62.5 Kw and only one lead can be used at a time.

The due date for proposal submission remains Thursday, September 6, 2018, at 3:00 PM (PDT).

VVTA RFP 2018-17 BATTERY ENERGY STORAGE AND
DEMAND RESPONSE
ADDENDUM NO. 2

All other terms and conditions of the RFP remain the same.

As stated in the RFP, all addenda must be acknowledged. Please use Attachment G of the RFP to acknowledge receipt of this addendum. Failure to acknowledge any addenda to this RFP may be cause to deem Bidder "Non-Responsive."

***** END OF ADDENDUM NO. 2 *****