

**VVTA RFP 2023-03
VICTORVILLE TRANSPORTATION CENTER RENOVATION
ADDENDUM NO. 2**

Tuesday, January 17, 2023

This addendum is provided to all known prospective proposers for clarification of the subject Request for Proposal (RFP).

The Timeline for this RFP remains as:

Last Day for Questions	5:00 PM PST, Friday, January 20, 2023
Addenda and Answers to questions	2:00 PM PST, Thursday, January 26, 2023
Proposal Due Date	3:00 PM PST, Thursday, February 2, 2023
Anticipated Award Date	March 2023

The following are questions that were posed during the job walk on 01/05/2023:

Q1: "What is the budget range for this project?"

A1: Approx. \$500,000.00

Q2: "What are the current security camera specifications?"

A2: These will be included in the following addendum.

Q3: "Does there need to be additional conduit installed for the cat5/6 cable?"

A3: If possible, please use the existing conduit.

Q4: "Does the Cat5/6 cable need to extend to the edge of the lot/property?"

A4: No.

Q5: "What is the estimation for this project?"

A5: See A1 – if this is regarding the proposed timeline – Per the Notice Inviting Proposals, the proposed timeline is approx. 120 days. However, that can be negotiated with the awarded proposer.

Q6: "What badge entry system and software does VVTA use at its other locations?"

A6: R2S system and Access IT software. The installation will be coordinated with the VVTA IT department

Q7: "What kind of flooring is required in the existing restrooms?"

A7: Resinous epoxy flooring.

VVTA RFP 2023-03
VICTORVILLE TRANSPORTATION CENTER RENOVATION
ADDENDUM NO. 2

Q8: "Does the contractor replace the tiles on the walls in the existing restrooms?"

A8: Only ones that may be damaged or missing.

Clarification:





There was some confusion as to where the wall between the Ticket office and the Driver's breakroom would be located. It has been determined that the division of the two rooms shall be after the column to the left of the east facing window.





There was a question regarding the extension of the pergola to the end of the sidewalk on the west end of the bus stops. VVTA prefers Bus stop shelters to be located on the sidewalk and not extending the pergola.

VVTA will require 17 bus stop benches to be installed in locations that do not have benches on the bus stop area.

The job walk sign in sheets are attached to the addendum for your reference, as well.

As stated in the RFP, all addenda must be acknowledged. Please use Attachment G of the RFP to acknowledge receipt of this addendum. Failure to acknowledge any addenda to this RFP may be cause to deem Bidder "Non-Responsive."

Company Name	Address	Phone	Fax	Representative Name	Signature	Email Address
VVTA	17150 Smokefreeest	760 995 3585		Nick Redwine		NRedwine@VVTA.org
Tjergensen Construction	9320 Daisy Rd. Oak Hills	760 947 4545		Lucas Charland		tjergensen@msn.com
VVTA	17150 Smokefree st	760 995 3580		Dustin Strandberg		dstrandberg@VVTA.org
VVTA	17150 Smokefree Hesperia CA 92345	760-995 45 3583		Christine Plasting		cplasting@VVTA.org

Company Name	Address	Phone	Fax	Representative Name	Signature	Email Address
ELY COMPANY	P.O. Box 1022 A.V. 92307	760-242-3881	760-242-6800	SKIP ELY		skip@elycomp any.com
Metro Builders & Engineers Group, Ltd.	2610 Avon St, Newport Beach, CA 92663	949-515-4350	949-515-4351	Udit Tambe		estimating@ metrobldrs.com
Z2 Construction	Santa ana	714- 863-4132		Annie Fox		estimating@ z2constructionco.com
Birdgroup	12033 JACK BOWY 909 Rancho Cuc	481-1813		Brian Orien		BOrien@Birdgrp.com