## VVTA RFP 2023-02 HESPERIA PERIMETER FENCE ADDENDUM NO. 3

Tuesday, March 7, 2023

This addendum is provided to all known prospective proposers for clarification of the subject Request for Proposal (RFP).

The purpose of this addendum is to address questions that have been posed on during the job walk on February 13, 2023, and prior to the deadline for questions posed prior to 2/24/2023 at 5:00 PM:

Q1: "Are we responsible for running the cabling, electrical, and conduit?

A1: Yes, the awarded contractor is responsible for the construction, supply, and installation of all cabling, wires, and conduit required for the gates, motors, communications, transponder/badge systems as required of proposer's design, including any controllers, power supplies, and additional hardware for the systems.

Q2: "What is the Badge Access System?"

A2: VVTA uses Software House iSTAR-PRO controllers and the RS2 Access IT! software.

The due date for proposals remains as 3:00 PM on Thursday, March 9, 2023.

As stated in the RFP, all addenda must be acknowledged. Please use Attachment E included in the RFP package to acknowledge receipt of this addendum. Failure to acknowledge any addenda to this RFP may be a cause to deem Potential Proposer as "Non-Responsive."

\*\*\*\*\*\*\*\*\* End of Addendum No. 3 \*\*\*\*\*\*\*\*\*